

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S010B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves A-80 VITAQ

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Valvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S011B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves A-80

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S012B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves DELTA

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S014B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves MINI FILTRO VITAQ

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S020B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves L-85 VITAQ

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S021B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves L-85

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S023B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves L-86

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S025B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves L-94

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S026B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves L-94 DELTA

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S030B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves COMBI VITAQ

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S031B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves COMBI

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S032B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves DUAL VITAQ

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1
-

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S033B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Angle valves A-80 TWIN VITAQ

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	10bar (145 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004 and OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S040B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Straight valves MINI

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004 and OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S041B

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Straight valves MINI VITAQ

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Instytut Techniki Budowlanej. Ul Filtrowa 1. 00-611 Warszawa. Krajowa Ocena Techniczna ITB-KOT-2021/2003 wydanie 1

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004 and OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

October 3, 2022
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

S042A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Straight valves MINI DELTA

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 95°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water installations
- Hot water networks

This product has been certified by:

- Eurofins, Expertises Environnementales ACS certificate 15ACC NY 104

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004 and OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager