

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

P070A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

CHECK VALVES

are manufactured in accordance with the following technical requirements:

- EN 13959 Anti-pollution check valves DN6 to DN250 inclusive family E, type A, B, C and D
- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 80°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water networks
- Water supply connections
- Plumbing networks

This product has been certified by:

- Our own laboratory in accordance with EN 13959

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

P071A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

SWING VALVES

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 80°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water networks
- Water supply connections
- Plumbing networks

This product has been certified by:

- Our own laboratory in accordance with ISO 5208 - Industrial valves, pressure testing of metal valves

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

P072A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

Y STRAINER

are manufactured in accordance with the following technical requirements:

- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 80°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water networks
- Water supply connections
- Plumbing networks

This product has been certified by:

- Our own laboratory in accordance with ISO 5208 - Industrial valves, pressure testing of metal valves

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

P073A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

FILTER

are manufactured in accordance with the following technical requirements:

- Main raw material used is stainless steel

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 80°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water networks
- Water supply connections
- Plumbing networks

This product has been certified by:

- Our own laboratory in accordance with ISO 5208 - Industrial valves, pressure testing of metallica valves

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

P074A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

GATE VALVE

are manufactured in accordance with the following technical requirements:

- EN 1213 Building valves. Copper alloy stop valves for potable water supply in building. Test and requirements.
- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 80°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water networks
- Water supply connections
- Plumbing networks

This product has been certified by:

- Our own laboratory in accordance with ISO 5208 - Industrial valves, pressure testing of metallica valves

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

P075A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

GATE VALVE ELASTIC CLOSURE

are manufactured in accordance with the following technical requirements:

- EN 1213 Building valves. Copper alloy stop valves for potable water supply in building. Test and requirements.
- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 80°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water networks
- Water supply connections
- Plumbing networks

This product has been certified by:

- Our own laboratory in accordance with ISO 5208 - Industrial valves, pressure testing of metal valves

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager

DECLARATION OF CONFORMITY

According to ISO/IEC 17050-1

P076A

Válvulas ARCO, S.L. located at Avda de Cid 16, Foios 46134, Valencia SPAIN; manufacturer of valves, accessories and systems for water, gas and heating; in conformity with the current regulations, DECLARES on its sole responsibility that the series:

LIMITER PRESSURE

are manufactured in accordance with the following technical requirements:

- EN 1567 Buiding valves. Water pressure reducing valves and combination pressure reducing valves. Requirements and tests
- Main raw material used is brass in conformity with the EN 12164 (CW614N) for machining and EN12165 (CW617N) for stamping. This brass is therefore suitable to be in contact with drinking water.
- Their thread ends are according to ISO 228

The working conditions of these valves are:

Nominal pressure	16 bar (232 psi)
Temperature range	0°C up to 50°C, excluding frozen

According to its technical features and materials, this series is intended to be used in:

- Drinking water networks
- Water supply connections
- Plumbing networks

This product has been certified by:

- Our own laboratory in accordance with ISO 5208 - Industrial valves, pressure testing of metallica valves

VALVULAS ARCO S.L. Quality Control System is certified with **ISO 9001:2008**, and also owns **ISO 14001: 2004** and **OHSAS 18001: 2007**, all them issued by **TÜV SÜD Management Service GmbH No. 12 100 42558 TMS**. Válvulas ARCO undertakes to provide reports, tests and technical information relative to any of mentioned products to secure the correct use of our products.

July 21, 2015
Valencia, SPAIN



Carlos López
Product Engineering Manager