

STEELMET ROMANIA S.A. 42nd DRUMUL INTRE TARLALE STR. 32982 BUCHAREST 3rd SECTOR

## **INSPECTION CERTIFICATE** Type 3.1 acc. EN 10204

**Certificate No: 1000516222** Delivery No: 0085252574 **DATE: 19.04.2022** 

Customer	STEELMET ROMANIA S.A.							
Cust's Ref No	0010032892			Cust's Part No				
Our Order No	1200129054 / 30	Quantity	660,00 MTR	Inspection Lot	020000761737			

Designation	CuT m 035,000x1,00x3000 AE HSH D S					
according to	THERMOGREEN according to Customer Specs, Mechanical properties and Surface quality acc.to EN 1057					
Material Chem. Anal.:	Cu-DHP CU>99,90-P:0,015-0,040 OK					

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODmin	mm	>=34,930	34,950	1
ODmax	mm	<=35,070	35,050	1
ODav	mm	34,940 - 35,060	35,000	1
Smin	mm	>=0,762	0,830	1
Smax	mm	<=0,932	0,860	1
Sav	mm	0,836 - 0,856	0,845	1
LENGTH	mm	>=3000	439,6	1
Rm	N/mm²	>=290,0	428,2	1
A50		>=3,0	8,0	1
C TOT. RES. IN.	mg/dm²	<=0,20	0,15	1
ECT EN 1971	%	100	OK	-

## **DECLARATION OF COMFORMITY**

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

**Athens** 

27.04.2022

Q.C. INSPECTOR

HLA

Q.A. MANAGER

D. SKARMOUTSOS

FORM N3



ISSUE: C REV: 2

COPPER @ ALLOYS EXTRUSION DIVISION:

Offices & Copper Tubes Plant (Mailing Address) 62nd km Athens-Lamia National Road Oinofyta - Viotia, GR 32011, Greece Tel.: +30 22620 48111 Fax: +30 22620 48911 www.halcor.com

Brass Rods ® Tubes Plant (Mailing Address) 59th km Athens- Lamia National Road Oinofyta - Viotia, GR 32011, Greece Tel.: +30 22620 53158

Foundry 60th km Athens-Lamia National Road Oinofyta -Viotia, GR 32011, Greece Tel.: +30 22620 53011, Fax: +30 22620 53095 Domestic Sales Dept Peripheral Unit of West Attica Municipality of Aspropyrgos Prari position-Moustaki
Industrial Park Area VIPA VIOPA EM